



Danish Governmental Gas Institute (DGP)
Tranegårdsvej 20
2900 Hellerup
Denmark

CE TYPE-EXAMINATION CERTIFICATE

Date: 12.08.96-rev.0

DANISH GOVERNMENTAL GAS INSTITUTE
hereby issues



type examination certificate
DG-3375

to
Schulz & Rackow
Gastechnik GMBH
D-35068 Gladenbach
Germany

regarding conformity with the Gas Appliance Directive (GAD)
90/396/EEC of the following appliance:


Appliance: LPG - High pressure regulator
(0.5 - 2 bar)
Manufacturer: Schulz & Rackow
Model: Type 552

We refer to the following material:

Annex 1: Appliance identification and technical data
Annex 3: Approval documentation

Countries of destination: Denmark

Danish Governmental Gas Institute


Helge K. Hansen

section manager, type-certification



Danish Governmental Gas Institute (DGP)
Tranegårdsvej 20
2900 Hellerup
Denmark

DG-3375
Annex 1

APPLIANCE IDENTIFICATION AND TECHNICAL DATA

Date: 12.08.96-rev.0

APPLIANCE IDENTIFICATION

Material group: 07.04 LPG-High pressure regulator
Type: Type 552
Manufacturer: SRG
Category: I₃B/P
Country of destination: Denmark

TECHNICAL DATA

Inlet pressure: 1.8 - 16 bar
Outlet pressure: 0.5 - 2 bar
Capacity: 4 kg/h
Temperature: -20° _ +50° C

Comments: The LPG pressure regulator must be used in connection with quick coupling cylinder valves, type 130 B, (connections no. 405 35 mm valves according to code og practise 15 point 4,2,1 from LG Gas Association, dated April 1992).